

**103.14 Alarm installations.**

A person who is not licensed pursuant to this chapter may plan, lay out, or install electrical wiring, apparatus, and equipment for components of alarm systems that operate at seventy volt/amps (VA) or less, only if the person is certified to conduct such work pursuant to chapter 100C. Installations of alarm systems that operate at seventy volt/amps (VA) or less are subject to inspection by state inspectors as provided in section 103.31, except that reports of such inspections, if the installation being inspected was performed by a person certified pursuant to chapter 100C, shall be submitted to the state fire marshal and any action taken on a report of an inspection of an installation performed by a person certified pursuant to chapter 100C shall be taken by or at the direction of the state fire marshal, unless the installation has been found to exceed the authority granted to the certificate holder pursuant to chapter 100C and therefore to be in violation of this chapter.

2007 Acts, ch 197, §24, 50

Referred to in §103.8, 103.22