

**751—11.6(8D) Power source to the fiberoptic termination site room.** The authorized facility shall maintain a constant source of power and adequate heating and cooling for the fiberoptic termination site room and for the equipment contained therein.