

875—140.2(89B) Agreement between an employer and fire department.

140.2(1) In instances where the posting of a sign for each hazardous chemical would be ambiguous or repetitive or where space is limited by the physical characteristics of the structure, or in situations, such as in a building, structure, or location where a wide variety of materials may be stored having varying degrees of hazards, the identifying symbol shall indicate the most severe degree of hazard in each category except when a high hazard rating would be misleading because of the presence of an insignificant quantity of the material requiring the rating.

140.2(2) The employer and the local fire department may enter into a written agreement providing for the posting of signs for the most hazardous chemical in each principal category. The agreement is subject to the approval of the division pursuant to the procedure for a waiver. If the waiver is approved, the employer shall post in the same location as the required posted signs a sign stating: “Signs not posted for all hazardous chemicals” in block letters at least three inches in height.

[ARC 8752C, IAB 1/8/25, effective 2/12/25]