

**199—45.2(476) Scope.**

**45.2(1)** This chapter applies to utilities, and distributed generation facilities seeking to operate in parallel with utilities, provided the facilities are not subject to the interconnection requirements of an affected system, the Federal Energy Regulatory Commission (FERC), the Midcontinent Independent System Operator, Inc. (MISO), the Southwest Power Pool (SPP), the Midwest Reliability Organization (MRO), or the SERC Reliability Corporation (SERC).

**45.2(2)** If the nameplate capacity of the facility is greater than 10 MVA, the interconnection customer and the utility shall start with the Level 4 review process and agreements under rule 199—45.11(476) and modify the process and agreements as needed by mutual agreement. In addition, the interconnection customer and the utility shall start with the technical standards under rule 199—45.3(476) and modify the standards as needed by mutual agreement. If the interconnection customer and the utility cannot reach mutual agreement, the interconnection customer may seek resolution through the rule 199—45.12(476) dispute process.

[ARC 8859B, IAB 6/16/10, effective 7/21/10; ARC 2917C, IAB 1/18/17, effective 2/22/17]