

**567—43.9(455B) Enhanced filtration and disinfection requirements for surface water and IGW systems serving at least 10,000 people.****43.9(1) General requirements.**

*a. Applicability.* The requirements of this rule constitute national primary drinking water regulations. This rule establishes the filtration and disinfection requirements that are in addition to criteria under which filtration and disinfection are required in 567—43.5(455B). The requirements of this rule are applicable, beginning January 1, 2002, to all public water systems using surface water or groundwater under the direct influence of surface water, in whole or in part, and which serve at least 10,000 people. This rule establishes or extends treatment technique requirements in lieu of maximum contaminant levels for the following contaminants: *Giardia lamblia*, viruses, heterotrophic plate count bacteria, *Legionella*, *Cryptosporidium*, and turbidity. Each surface water or groundwater under the direct influence of surface water system serving at least 10,000 people must provide treatment of its source water that complies with these treatment technique requirements and they are in addition to those identified in subrule 43.5(1). The treatment technique requirements consist of installing and properly operating water treatment processes that reliably achieve:

(1) At least 99 percent (2-log) removal of *Cryptosporidium* between a point where the raw water is not subject to recontamination by surface water runoff and a point downstream before or at the first customer for filtered systems.

(2) Compliance with the profiling and benchmark requirements under 43.9(2).

(3) The department may require other surface water or groundwater under the direct influence of surface water systems to comply with this rule, through an operation permit.

*b. Compliance determination.* A public water system subject to the requirements of this rule is considered to be in compliance with the requirements of 43.9(1)“a” if it meets the applicable filtration requirements in either 43.5(3) or 43.9(3) and the disinfection requirements in 43.5(2) and 43.6(2).

*c. Prohibition of new construction of uncovered intermediate or finished water storage facilities.* Systems that are required to comply with this rule may construct only covered intermediate or finished water storage facilities. For the purposes of this rule, an intermediate storage facility is defined as a storage facility or reservoir after the clarification treatment process.

*d. Systems with populations that increased after January 1, 2002, to more than 10,000 people served.* Systems using surface water or influenced groundwater sources that did not conduct optional monitoring under 43.9(2) because they served fewer than 10,000 persons when such monitoring was required, but serve more than 10,000 persons prior to January 1, 2005, must comply with 43.9(1), 43.9(3), 43.9(4), and 43.9(5). These systems must also consult with the department to establish a disinfection benchmark. A system that decides to make a significant change to its disinfection practice as described in 43.9(2)“c”(1)“1” through “4” must consult with the department prior to making such a change.

**43.9(2) Disinfection profiling and benchmarking.**

*a. Determination of systems required to profile.* A public water system subject to the requirements of this rule must determine its total trihalomethane (TTHM) and haloacetic acid (HAA5) annual averages using the procedures listed below. The annual average is the arithmetic average of the quarterly averages of four consecutive quarters of monitoring. Both the TTHM and HAA5 samples must be collected as paired samples during the same time period in order for each parameter to have the same annual average period for result comparison. A paired sample is one that is collected at the same location and time and is analyzed for both TTHM and HAA5 parameters.

(1) Allowance of information collection rule data. Those systems that collected data under the provisions of the federal Information Collection Rule listed in Code of Federal Regulations Title 40, Part 141, Subpart M, must use the results of the TTHM and HAA5 samples collected during the last four quarters of monitoring required under 40 CFR 141.142. The system must have submitted the results of the samples collected during the last 12 months of required monitoring.

(2) Systems that have not collected TTHM and HAA5 data under 43.9(2)“a”(1). Those systems that have not collected four consecutive quarters of paired TTHM and HAA5 samples as described under 43.9(2)“a”(1) must comply with all other provisions of this subrule as if the HAA5 monitoring had been

conducted and the results of that monitoring required compliance with 43.9(2) “b.” The system that elects this option must notify the department in writing of its decision.

(3) The department may require that a system use a more representative annual data set than the data set determined under 567—subparagraph 42.9(2) “a”(1) for the purpose of determining applicability of the requirements of this subrule.

(4) Profiling determination criteria. Any system having either a TTHM annual average greater than 0.064 mg/L or an HAA5 annual average greater than 0.048 mg/L during the period identified in 43.9(2) “a”(1) through (3) must comply with 43.9(2) “b.”

*b. Disinfection profiling.*

(1) Applicability. Any system that meets the criteria in 43.9(2) “a”(4) must develop a disinfection profile of its disinfection practice for a period of up to three years.

(2) Monitoring requirements. The system must monitor daily for a period of 12 consecutive calendar months to determine the total logs of inactivation for each day of operation, based on the CT<sub>99.9</sub> values in Tables 1 through 8 in Appendix A, as appropriate, through the entire treatment plant. This system must begin this monitoring as directed by the department. As a minimum, the system with a single point of disinfectant application prior to entrance to the distribution system must conduct the monitoring in 43.9(2) “b”(2) “1” through “4.” A system with more than one point of disinfectant application must conduct the monitoring in 43.9(2) “b”(2) “1” through “4” for each disinfection segment. The system must monitor the parameters necessary to determine the total inactivation ratio, using analytical methods in 43.5(4) “a” as follows:

1. The temperature of the disinfected water must be measured once per day at each residual disinfectant concentration sampling point during peak hourly flow.
2. If the system uses chlorine, the pH of the disinfected water must be measured once per day at each chlorine residual disinfectant concentration sampling point during peak hourly flow.
3. The disinfectant contact time(s) (“T”) must be determined for each day during peak hourly flow.
4. The residual disinfectant concentration(s) (“C”) of the water before or at the first customer and prior to each additional point of disinfection must be measured each day during peak hourly flow.

(3) Use of existing data. A system that has existing operational data may use those data to develop a disinfection profile for additional years, in addition to the disinfection profile generated under 43.9(2) “b”(2). Such systems may use these additional yearly disinfection profiles to develop a benchmark under the provisions of 43.9(2) “c.” The department must determine whether these operational data are substantially equivalent to data collected under the provisions of 43.9(2) “b”(2). These data must also be representative of inactivation through the entire treatment plant and not just of certain treatment segments.

(4) Calculation of the total inactivation ratio. The system must calculate the total inactivation ratio as follows, using the CT<sub>99.9</sub> values from Tables 1 through 8 listed in Appendix A:

1. If the system uses only one point of disinfectant application, the system may determine the total inactivation ratio for the disinfection segment based on either of the following two methods:

- Determine one inactivation ratio (CT<sub>calc</sub>/CT<sub>99.9</sub>) before or at the first customer during peak hourly flow.
- Determine successive CT<sub>calc</sub>/CT<sub>99.9</sub> values, representing sequential inactivation ratios, between the point of disinfectant application and a point before or at the first customer during peak hourly flow. Under this alternative, the system must calculate the total inactivation ratio by determining (CT<sub>calc</sub>/CT<sub>99.9</sub>) for each sequence and then adding the (CT<sub>calc</sub>/CT<sub>99.9</sub>) values together to determine Σ(CT<sub>calc</sub>/CT<sub>99.9</sub>).

2. If the system uses more than one point of disinfectant application before the first customer, the system must determine the CT value of each disinfection segment immediately prior to the next point of disinfectant application, or for the final segment, before or at the first customer, during peak hourly flow. The CT<sub>calc</sub>/CT<sub>99.9</sub> value of each segment and Σ(CT<sub>calc</sub>/CT<sub>99.9</sub>) must be calculated using the method in 43.9(2) “b”(4) “1.”

3. The system must determine the total logs of inactivation by multiplying the value calculated in 43.9(2) “b”(4) “1” or “2” by 3.0.

(5) Systems using chloramines or ozone. A system that uses either chloramines or ozone for primary disinfection must also calculate the logs of inactivation for viruses using a method approved by the department.

(6) Profile retention requirements. The system must retain disinfection profile data in graphic form, as a spreadsheet, or in some other format acceptable to the department for review as part of sanitary surveys conducted by the department. The department may require the system to submit the data to the department directly or as part of a monthly operation report.

*c. Disinfection benchmarking.*

(1) Significant change to disinfection practice. Any system required to develop a disinfection profile under the provisions of 43.9(2)“a” or “b” that decides to make a significant change to its disinfection practice must obtain department approval prior to making such change. Significant changes to disinfection practice are:

1. Changes to the point of disinfection;
2. Changes to the disinfectant(s) used in the treatment plant;
3. Changes to the disinfection process; and
4. Any other modification identified by the department.

(2) Calculation of the disinfection benchmark. Any system that is modifying its disinfection practice must calculate its disinfection benchmark using the procedure specified below:

1. For each year of profiling data collected and calculated under 43.9(2)“b,” the system must determine the lowest average monthly *Giardia lamblia* inactivation in each year of profiling data. The system must determine the average *Giardia lamblia* inactivation for each calendar month for each year of profiling data by dividing the sum of daily *Giardia lamblia* inactivation by the number of values calculated for that month.

2. The disinfection benchmark is the lowest monthly average value (for systems with one year of profiling data) or average of lowest monthly average values (for systems with more than one year of profiling data) of the monthly logs of *Giardia lamblia* inactivation in each year of profiling data.

(3) A system that uses either chloramines or ozone for primary disinfection must also calculate the disinfection benchmark for viruses using a method approved by the department.

(4) The system must submit the following information to the department as part of its consultation process:

1. A description of the proposed change;
2. The disinfection profile for *Giardia lamblia* (and, if necessary, viruses) under 43.9(2)“b” and the disinfection benchmark as required by 43.9(2)“c”(2); and
3. An analysis of how the proposed change will affect the current levels of disinfection.

**43.9(3) Filtration.**

*a. Conventional filtration treatment or direct filtration.*

(1) Turbidity requirement in 95 percent of samples. For systems using conventional filtration or direct filtration, the turbidity level of representative samples of a system’s filtered water (combined filter effluent or CFE) must be less than or equal to 0.3 NTU in at least 95 percent of the measurements taken each month, measured as specified in 43.5(4)“a”(1) and 43.5(4)“b”(1).

(2) Maximum turbidity level. The turbidity level of representative samples of a system’s filtered water (combined filter effluent or CFE) must at no time exceed 1 NTU, measured as specified in 43.5(4)“a”(1) and 43.5(4)“b”(1). If at any time the combined filter effluent turbidity exceeds 1 NTU, either in a grab sample used for compliance or in a continuously monitored flow, the system must inform the department as soon as possible, but no later than 24 hours after the exceedance is known, in accordance with the public notification requirements under 567—subparagraph 42.1(3)“b”(3).

(3) Systems with lime-softening treatment. A system that uses lime softening may acidify representative samples prior to analysis using a protocol approved by the department.

*b. Filtration technologies other than conventional filtration treatment, direct filtration, slow sand filtration, or diatomaceous earth filtration.* The department may allow a public water system to use a filtration technology not listed in 43.9(3)“a” or 43.5(3)“c” or “d” if it demonstrates to the department, using pilot plant studies or other means, that the alternative filtration technology, in combination with

disinfection treatment that meets the requirements of 43.5(2), consistently achieves 99.9 percent removal or inactivation of *Giardia lamblia* cysts, 99.99 percent removal or inactivation of viruses, and 99 percent removal of *Cryptosporidium* oocysts and the department approves the use of the filtration technology. For each approval, the department will set turbidity performance requirements that the system must meet at least 95 percent of the time and the requirement that the system shall not exceed at any time at a level that consistently achieves 99.9 percent removal or inactivation of *Giardia lamblia* cysts, 99.99 percent removal or inactivation of viruses, and 99 percent removal of *Cryptosporidium* oocysts.

**43.9(4) Filtration sampling requirements.**

*a. Monitoring requirements for systems using filtration treatment.* In addition to monitoring required by 43.5(4), a public water system subject to the requirements of this rule that provides conventional filtration treatment or direct filtration must conduct continuous monitoring of turbidity for each individual filter using an approved method in 43.5(4) "a"(1) and must calibrate turbidimeters at least every 90 days with a primary standard. The calibration of each turbidimeter used for compliance must be verified at least once per week with a primary standard, secondary standards, or the manufacturer's proprietary calibration confirmation device or by a method approved by the department. If the verification is not within plus or minus 0.05 NTU for measurements of less than or equal to 0.5 NTU, or within plus or minus 10 percent of measurements greater than 0.5 NTU, then the turbidimeter must be recalibrated. Systems must record the results of individual filter monitoring every 15 minutes.

*b. Failure of the continuous turbidity monitoring equipment.* If there is a failure in the continuous turbidity monitoring equipment, the system must conduct grab sampling every four hours in lieu of continuous monitoring until the turbidimeter is repaired and back online. A system has a maximum of five working days after failure to repair the equipment, or else it is in violation.

**43.9(5) Reporting and record-keeping requirements.** In addition to the reporting and record-keeping requirements in 567—paragraph 42.4(3) "c," a system subject to the requirements of this rule that provides conventional filtration treatment or direct filtration must report monthly to the department the information specified in 43.9(5) "a" and "b" beginning January 1, 2002. In addition to the reporting and record-keeping requirements in 567—paragraph 42.4(3) "c," a system subject to the requirements of this rule that provides filtration approved under 43.9(3) "b" must report monthly to the department the information specified in 43.9(5) "a" beginning January 1, 2002. The reporting in 43.9(5) "a" is in lieu of the reporting specified in 567—subparagraph 42.4(3) "c"(1).

*a. Turbidity.* Turbidity measurements as required by 43.9(3) must be reported in a format acceptable to the department and within ten days after the end of each month that the system serves water to the public. Information that must be reported includes:

(1) The total number of filtered water (combined filter effluent or CFE) turbidity measurements taken during the month;

(2) The number and percentage of filtered water (combined filter effluent or CFE) turbidity measurements taken during the month which are less than or equal to the turbidity limits specified in 43.9(3) "a" or "b"; and

(3) The date and value of any combined filter effluent or CFE turbidity measurements taken during the month which exceed 1 NTU for systems using conventional filtration treatment or direct filtration or which exceed the maximum level set by the department under 43.9(3) "b."

(4) The dates and summary of calibration and verification of all compliance turbidimeters.

*b. Individual filter turbidity monitoring.* Systems must maintain the results of individual filter turbidity per monitoring taken under 43.9(4) for at least three years. Systems must report to the department that they have conducted individual filter turbidity monitoring under 43.9(4) within ten days after the end of each month that the system serves water to the public. Systems must report to the department individual filter turbidity measurement results taken under 43.9(4) within ten days after the end of each month that the system serves water to the public only if measurements demonstrate one or more of the conditions specified in 43.9(5) "b"(1) through (4). Systems that use lime softening may apply to the department for alternative exceedance levels for the levels specified in 43.9(5) "b"(1) through (4) if they can demonstrate that higher turbidity levels in individual filters are due to lime carryover only and not due to degraded filter performance.

(1) For any individual filter that has a measured turbidity level of greater than 1.0 NTU in two consecutive measurements taken 15 minutes apart, the system must report the filter number, the turbidity measurement, and the date(s) on which the exceedance occurred. In addition, the system must either produce a filter profile for the filter within seven days of the exceedance (if the system is not able to identify an obvious reason for the abnormal filter performance) and report that the profile has been produced or report the obvious reason for the exceedance.

(2) For any individual filter that has a measured turbidity level of greater than 0.5 NTU in two consecutive measurements taken 15 minutes apart anytime following the first four hours of continuous filter operation after the filter has been backwashed or otherwise taken offline, the system must report the filter number, the turbidity, and the date(s) on which the exceedance occurred. In addition, the system must either produce a filter profile for the filter within seven days of the exceedance (if the system is not able to identify an obvious reason for the abnormal filter performance) and report that the profile has been produced or report the obvious reason for the exceedance.

(3) For any individual filter that has a measured turbidity level of greater than 1.0 NTU in two consecutive measurements taken 15 minutes apart at any time in each month of three consecutive months, the system must report the filter number, the turbidity measurement, and the date(s) on which the exceedance occurred. In addition, the system must conduct a self-assessment of the filter within 14 days of the exceedance and report that the self-assessment was conducted. The self-assessment must consist of at least the following components: assessment of filter performance; development of a filter profile; identification and prioritization of factors limiting filter performance; assessment of the applicability of corrections; and preparation of a filter self-assessment report.

(4) For any individual filter that has a measured turbidity level of greater than 2.0 NTU in two consecutive measurements taken 15 minutes apart at any time in each month of two consecutive months, the system must report the filter number, the turbidity measurement, and the date(s) on which the exceedance occurred. In addition, the system must arrange for a comprehensive performance evaluation to be conducted by the department or a third party approved by the department no later than 30 days following the exceedance and have the evaluation completed and submitted to the department no later than 90 days following the exceedance.

*c. Additional reporting requirement for turbidity combined filter effluent.*

(1) If at any time the turbidity exceeds 1 NTU in representative samples of filtered water (combined filter effluent or CFE) in a system using conventional filtration treatment or direct filtration, the system must consult with the department as soon as practical, but no later than 24 hours after the exceedance is known, in accordance with the public notification requirements under 567—subparagraph 42.1(3) “b”(3).

(2) If at any time the turbidity in representative samples of filtered water (combined filter effluent or CFE) exceeds the maximum level set by the department under 43.9(3) “b” for filtration technologies other than conventional filtration treatment, direct filtration, slow sand filtration, or diatomaceous earth filtration, the system must consult with the department as soon as practical, but no later than 24 hours after the exceedance is known, in accordance with the public notification requirements under 567—subparagraph 42.1(3) “b”(3).

[ARC 9915B, IAB 12/14/11, effective 1/18/12; ARC 3735C, IAB 4/11/18, effective 5/16/18]