

**567—69.14(455B) Aerobic treatment units.** General requirements for aerobic treatment units are as follows:

**69.14(1) Use.** Aerobic treatment units may be used only when the administrative authority determines that the site is unacceptable for a soil absorption system or an intermittent sand filter. Because of the higher maintenance requirements of aerobic treatment units, preference should be given to packed bed media filters, where conditions allow.

**69.14(2) Certification.** All aerobic treatment units shall be certified by an ANSI-accredited third-party certifier to meet National Sanitation Foundation Standard 40, Class I, including appendices (March 2008), or equivalent testing as determined by the department.

**69.14(3) Installation and operation.** All aerobic treatment units shall be installed, operated and maintained in accordance with the manufacturer's instructions and the requirements of the administrative authority. The aerobic treatment units shall have a minimum treatment capacity of 150 gallons per bedroom per day or 500 gallons, whichever is greater.

**69.14(4) Pre-tank required.** All aerobic treatment units shall be preceded by a septic or trash tank with a minimum capacity of 500 gallons. The trash tank may be a single-compartment tank. A trash tank built in as part of the aerobic treatment unit's design satisfies this requirement.

**69.14(5) Effluent treatment.** The effluent from aerobic treatment units shall receive additional treatment through the use of intermittent sand filters or soil absorption systems of a magnitude prescribed in subrule 69.9(2) for pretreated effluent.

**69.14(6) Maintenance contract.** Prior to installation, a maintenance contract for the proper monitoring and servicing of the entire treatment system shall be established between the owner and a certified technician. A maintenance contract is required for the life of the system. All monitoring and servicing shall be performed by a manufacturer's certified technician. Manufacturers are responsible for ensuring that an adequate number of certified technicians are available to service all aerobic treatment units at the specified intervals. Aerobic treatment units shall be inspected for proper operation at least twice a year at six-month intervals by the certified technician.

**69.14(7) Effluent sampling.** The discharge point of the aerobic treatment unit system shall be accessible for effluent sampling, or a sampling port shall be installed in the discharge line. All aerobic treatment unit systems that have an open discharge shall be sampled in accordance with the requirements of NPDES General Permit No. 4 if applicable.

[ARC 7569B, IAB 2/11/09, effective 3/18/09; ARC 0208C, IAB 7/11/12, effective 8/15/12]