

**567—72.8(455B) Water supply treatment facilities.** The following criteria shall apply to water supply treatment facilities.

**72.8(1) Location.** Water supply treatment facilities shall not be located so as to individually or collectively conflict with 567—75.4(455B) governing the establishment of encroachment limits.

**72.8(2) Flood protection.** Flood protection for water supply treatment facilities shall be provided to at least the level necessary for high damage potential buildings or building complexes.