

641—86.6(156) Crematorium chambers.

- 86.6(1)** Cremation chambers shall be installed according to the manufacturer's recommendations.
- 86.6(2)** Cremation chambers shall be vented to the outside of the building.
- 86.6(3)** There shall be a means to bring in a fresh air supply to aid in combustion.
- 86.6(4)** The room where the cremation chamber is located shall have adequate exhaust to prevent heat buildup.
- 86.6(5)** The cremation chamber shall be cleaned after each use, with cremated remains and pulverized materials being placed in containers as defined in 645—100.1(156).