

661—211.11(86GA,SF2219) Carbon monoxide alarms—required. Carbon monoxide alarms are required in the following buildings if the building is served by a fuel-burning heater, fuel-burning furnace, fuel-burning appliance, fuel-burning fireplace, or has an attached garage.

211.11(1) *New construction.* Multiple-unit residential buildings and single-family residences for which construction is begun on or after July 1, 2018.

211.11(2) *Existing buildings.* Single-family rental units, single-family residences, and multiple-unit residential buildings.

[ARC 3662C, IAB 2/28/18, effective 2/7/18]