

661—211.14(86GA,SF2219) Carbon monoxide alarms—power source.

211.14(1) *New construction—power source.* In buildings for which construction is begun on or after July 1, 2018, carbon monoxide alarms shall receive their primary power from the building wiring when such wiring is served from a commercial source. Wiring shall be permanent and without a disconnecting switch other than that required for overcurrent protection and shall be equipped with a battery backup.

211.14(2) *Wiring installation.* Any installation of wiring and equipment shall comply with 661—Chapter 504, Standards for Electrical Work, and requirements established by the manufacturer of the equipment serviced by the wiring.

211.14(3) *Existing buildings—power source.* New and replacement carbon monoxide alarms installed in existing buildings may be solely battery operated or may plug into an electrical socket and have a battery backup.

[ARC 3662C, IAB 2/28/18, effective 2/7/18]