

761—115.11(306A) Vertical overhead clearance requirements.

115.11(1) *Conformance to standards.* The vertical clearance for overhead utility facilities and the lateral and vertical clearances for bridges shall conform to accepted industry standards as well as applicable codes and regulations.

115.11(2) *Minimum vertical clearance.* In no event shall the vertical clearance be less than 20 feet above the roadway for all overhead utilities.