

875—90.14(89) Temporary objects.

90.14(1) *Certificate to operate.* A certificate to operate a temporary object shall expire one year from the date of issuance or when the temporary object is disconnected.

90.14(2) *Inspections.*

a. An internal inspection and hydrostatic test pursuant to the National Board Inspection Code shall be performed on site at a new location before a temporary object is started up. Once a temporary object has been placed into normal operation, an external operating inspection shall be performed.

b. An inspection on a temporary object that remains at the same location and is in continuous service longer than one year shall be performed according to the inspection schedule of Iowa Code section 89.3.

[ARC 5977C, IAB 10/20/21, effective 11/24/21]