

**875—93.1(89) Scope.** This chapter sets forth requirements in addition to those contained in 875—Chapter 92 for boilers that:

1. Have a heating surface of 20 square feet or less;
2. Have a gross volume of 5 cubic feet or less, excluding casing and insulation;
3. Have an inside shell diameter of 16 inches or less;
4. Have 100 psig maximum allowable working pressure; and
5. Were installed prior to September 20, 2006.

For objects covered by this chapter, if there is a conflict between this chapter and Chapter 92, this chapter shall govern the issue.