

875—93.5(89) Steam stop valves. Each steam line from a miniature power boiler shall be provided with a stop valve located as close to the boiler shell or drum as is practicable except when the boiler and steam receiver are operated as a closed system.

[ARC 8283B, IAB 11/18/09, effective 1/1/10]