

**641—81.2(138) Water supply.**

**81.2(1) General.** The following standards apply to the water supply:

- a. The water supply will be of a safe bacterial and chemical quality.
- b. Where a public water supply is available, such water will be used in the camp. If a private water source under pressure is provided, the water system will be capable of delivering at least 35 gallons per person per day to the camp site.
- c. Cistern supplies consisting of roof or other surface runoff water will not be used for drinking or culinary purposes.
- d. The adequacy of a well as a source of water for drinking or culinary purposes will be determined by inspection and bacteriological examination. Defects found by inspection or contaminated samples will be sufficient grounds for requiring repair, chlorination or condemnation of the well.
- e. Water containing 45 or more parts per million of nitrates will not be used for drinking or preparation of formula for infants under one year of age. When the supply contains nitrates in the quantity above, water for infant feeding will be obtained from another source that has been tested and found to be bacterially satisfactory and contains less than 45 parts per million of nitrates. A water supply containing 45 or more parts per million of nitrates will be placarded or posted stating the water will not be used for infant feeding.
- f. Hand-pump bases will be of the solid one-piece type bolted, including suitable gaskets, secured to the well casing by thread or weld connection. Handpumps secured to the platform by bolts cast in the concrete will be provided with a rubber or neoprene gasket between the pump base and the platform to ensure a watertight joint.
- g. The pump head will be of a type designed to prevent external water or other contaminating material from entering the water chamber.
- h. The pump spout will be of the closed, downward-directed type.

**81.2(2) Existing pump pits.** Existing pump pits may be approved if the construction conforms to the following minimum standards:

- a. Walls, floor and top of pit are of watertight concrete or masonry construction or equivalent. The well casing extends at least 6 inches above the pit floor.
- b. A positive seal is provided for the annular opening between the casing wall and the drop pipe.
- c. A positive drain is provided by either a watertight sump and automatic sump pump discharging with at least a 6-inch free fall above the ground surface or an independent drain line discharging to the ground surface above any possible flood level. Pit drains discharging to any other drain or sewer are prohibited.

**81.2(3) Water supply systems.** The water supply system shall be installed so as to prevent backflow of contaminated water from appliances, fixtures, drains and sewers and have no cross-connections with any nonpotable supply or any other water supply that does not comply with these rules.

**81.2(4) Water tanks.** All water to be hauled for a camp will be obtained from an approved source. All equipment used for hauling or storage of potable water will be thoroughly cleaned and disinfected with a solution containing at least 200 parts per million of chlorine immediately before use. No equipment, tanks or reservoirs used for hauling or storing potable water can be used for any other purpose.

[ARC 8909C, IAB 2/19/25, effective 3/26/25]