

641—81.6(138) Safety and fire.

81.6(1) *Fire exits.* Fire exits shall consist of:

- a. Shelters of one-story construction housing less than ten persons: two means of escape, one of which may be a readily accessible window with an openable space of at least 24 by 24 inches.
- b. Sleeping quarters designed for ten or more persons, central dining facilities and common assembly rooms: at least two doors remotely separated so as to provide alternate means of escape.
- c. Floors, above the first floor, used for sleeping quarters or common assembly rooms: a stairway and a permanent affixed exterior ladder or a second stairway.

81.6(2) *Shelter spacing.* There shall be at least ten feet of space in all directions between shelters.

[ARC 8909C, IAB 2/19/25, effective 3/26/25]