

**875—90.1(89) Purpose and scope.** These rules institute administrative and operational procedures for implementation of Iowa Code chapter 89. An object is not considered “under pressure” and is not within the scope of Iowa Code chapter 89 when there is clear evidence that the manufacturer did not intend it to be operated at more than 3 psi and the object is operating at 3 pounds per square inch (psi) or less. Jurisdiction is limited to objects, appurtenances, controls, safety devices, and equipment rooms as required by Iowa rules.

[ARC 8887C, IAB 2/19/25, effective 3/26/25]