

875—91.11(89) Condensate return tank. Condensate return tanks shall be equipped with at least two vents or a vent and overflow pipe to protect against a loose float plugging a single connection.
[ARC 8894C, IAB 2/19/25, effective 3/26/25]