

**875—91.5(89) Pipe, valve, and fitting requirements.** Pipes, valves, and fittings subject to the effects of galvanic action shall not be used on objects covered by these rules. Dielectric fittings shall be used where dissimilar metals are joined.

[ARC 8894C, IAB 2/19/25, effective 3/26/25]