

**875—93.5(89) Steam stop valves.** Each steam line from a miniature power boiler shall be provided with a stop valve located as close to the boiler shell or drum as is practicable except when the boiler and steam receiver are operated as a closed system.

[ARC 8889C, IAB 2/19/25, effective 3/26/25]