

**875—93.8(89) Blowoff.** Miniature power boilers shall be equipped with a blowoff connection, not less than ½-inch pipe size, located to drain from the lowest water space practicable. The blowoff shall be equipped with a valve or cock not less than ½-inch pipe size.

[ARC 8889C, IAB 2/19/25, effective 3/26/25]