

875—94.1(89) Scope. This chapter applies to:

94.1(1) Steam boilers for operation at pressures not exceeding 15 psig;

94.1(2) Hot water heating boilers for operation at pressures not exceeding 160 psig or temperatures not exceeding 250 degrees F at or near the boiler outlet;

94.1(3) Hot water supply boilers.

[ARC 8890C, IAB 2/19/25, effective 3/26/25]