

**567—119.5(455D,455B) Tanks.**

**119.5(1) *Aboveground.*** In addition to the requirements imposed by the office of the state fire marshal, the following standards are applicable to aboveground waste oil collection tanks:

*a.* The tank shall be of sufficient size to handle the projected quantities of used oil to be returned to this specific collection site.

*b.* The tank shall be designed and maintained to prevent the spillage or discharge of waste oil. Tanks must be set upon an impermeable surface engineered to contain potential spills.

*c.* Absorbent material shall be available at the tank site for use by the operator to control waste oil spillage or discharge.

*d.* The tank shall have a level gauge or some other adequate means for checking the oil level within the tank.

*e.* The tank shall be constructed in accordance with American Petroleum Institute specifications and standards.

**119.5(2) *Underground.*** Underground storage tanks used to collect or store waste oil shall comply with the standards in part 8 of division IV of Iowa Code chapter 455B, entitled “Underground Storage Tanks,” and the promulgated rules, Iowa Administrative Code, 567—Chapters 135 and 136.