

875—91.10(89) Clearance.

91.10(1) All objects installed prior to September 20, 2006, shall be so located that adequate space is provided for the proper operation, inspection, and necessary maintenance and repair of the object and its appurtenances.

91.10(2) This subrule applies to installations and reinstallations after September 20, 2006. Minimum clearance on all sides of objects shall be 24 inches, or the manufacturer's recommended service clearances if they allow sufficient room for inspection. Where a manufacturer identifies in the installation manual or any other document that the unit requires more than 24 inches of service clearance, those dimensions shall be followed. Manholes shall have five feet of clearance between the manhole opening and any wall, ceiling or piping that would hinder entrance or exit from the object.