

875—91.11(89) Fall protection. Safe access to all necessary parts of boilers over eight feet tall shall be provided by a runway platform or fall protection system consistent with the requirements below.

91.11(1) Runway platform. A steel runway platform in compliance with the criteria of 29 CFR 1910.23 and 1910.27 shall be installed across the tops of objects or at some other convenient level for the purpose of affording safe access. All runways shall have at least two means of exit remotely located from each other.

91.11(2) Fall protection system. A fall protection system shall be in compliance with the requirements of 29 CFR 1910.132.