

661—550.8(103) Scheduling of inspections. Pursuant to Iowa Code section 103.31, electrical inspections will be scheduled within three business days of the receipt of the request. If an inspection for which a timely request has been made is not completed within three business days of the completion of the installation, a licensee who completed the installation may energize any new circuits included in the installation, although the installation remains subject to condemnation and disconnection if found to be out of compliance with any applicable provision of rule 661—550.3(103) when inspected.

[ARC 9033C, IAB 3/19/25, effective 7/1/25]