IAC Ch 90, p.1

875—90.14(89) Temporary boilers. A certificate to operate a temporary boiler shall expire one year from the date of issuance or when the temporary boiler is disconnected. Inspections on temporary boilers that remain in one location longer than one year shall be performed according to the inspection schedule of Iowa Code section 89.3. A temporary boiler that is installed at a different location less than a year since the prior internal inspection of the boiler shall be subjected to a hydrostatic test pursuant to the National Board Inspection Code or to an internal inspection, at the discretion of the inspector.