

481—481.4(138) Bathing facilities.

481.4(1) Showers shall be supplied with hot and cold water under pressure and be sufficiently enclosed to provide privacy for the user. An adjacent, enclosed dry area will be provided for dressing. No duckboards, mats or other such accessories will be permitted.

481.4(2) Automatic water-heating equipment, or storage tanks with hand-fired heating coils, shall be equipped with combination pressure and temperature relief valves or separate pressure and temperature relief valves, located in the top one-eighth or not more than three inches above the top of the tank served. Pressure relief valves may be located adjacent to the tank. Gas-fired or other combustion-type water heaters shall be vented to the outside atmosphere.

[ARC 8909C, IAB 2/19/25, effective 3/26/25; Editorial change: IAC Supplement 4/2/25]