

**661—301.9(103A) Fuel gas piping requirements.** Fuel gas piping shall comply with the requirements of rule 641—25.3(105) and NFPA 54, ANSI Z223.1-2012, National Fuel Gas Code, 2012 Edition, published by the National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471. Liquefied petroleum gas facilities and appliances shall comply with rule 661—226.1(101).  
[ARC 8305B, IAB 11/18/09, effective 1/1/10; ARC 2492C, IAB 4/13/16, effective 5/18/16]