

**875—91.20 (89) CSD-1 reports and related documentation.** Documentation required by this rule shall be kept on site and shall be available for inspection.

**91.20(1)** The requirements of this rule do not apply to:

- a.* An object within the scope of 875—Chapter 95;
- b.* An object within the scope of 875—Chapter 96;
- c.* A hot water supply boiler covered by ASME Section IV, Part HLW; or
- d.* A boiler with a fuel input rating greater than or equal to 12,500,000 Btu per hour, falling within the scope of NFPA 85, Boiler and Combustion Systems Hazards Code.

**91.20(2)** The installer shall complete a Manufacturer's/Installing Contractor's Report for ASME CSD-1 (CSD-1 report) for each newly installed or reinstalled object.

**91.20(3)** A person who installs a new burner, new gas train, or new controller on an object shall complete a CSD-1 report.

**91.20(4)** A person who replaces a part or component of an object shall complete the relevant portions of the CSD-1 report unless the replacement satisfies the design specifications. A copy of an invoice containing the same information as the relevant portions of the CSD-1 report is an acceptable alternative.

[**ARC 8283B**, IAB 11/18/09, effective 1/1/10; **ARC 9232B**, IAB 11/17/10, effective 12/22/10; **ARC 1964C**, IAB 4/15/15, effective 5/20/15]