

661—221.16(101) Leaks, spills, or damage. Any leak from, spill from, or damage to a storage tank shall:

221.16(1) Be reported to the local fire department and, if required by law, to the department of natural resources.

221.16(2) Be placed out of service until the leak or damage has been repaired.

221.16(3) Have a sign placed prominently on the tank stating that the tank is out of service and that no flammable or combustible liquid shall be placed into the tank until required repairs have been completed.

[ARC 9181C, IAB 4/30/25, effective 6/4/25]