

**567—49.19(455B) Filters, water treatment equipment, and sampling faucets.**

**49.19(1)** Filters and water treatment equipment shall be installed and operated in accordance with manufacturers' directions.

**49.19(2)** In all pressure water systems, provision shall be made for collection of water samples directly from the well by installation of a sampling faucet before the pressure tank, prior to encountering any water treatment equipment.

*a.* The sampling faucet shall be installed at least 12 inches above the floor, have a downturned spout, and be in an accessible location.

*b.* All sample faucets shall be metal and have a smooth (nonthreaded) outlet.

[ARC 9196C, IAB 5/14/25, effective 6/18/25]