

567—49.25(455B) Water sampling and analysis.

49.25(1) The owner of a new, reconstructed, or rehabilitated well shall submit a water sample to a certified laboratory for coliform bacteria and nitrate analysis, or allow the administrative authority to collect this water sample. The water sample shall be collected at least 10 days after, but not more than 30 days after, a well is put into service following construction, reconstruction, or rehabilitation. The analysis results shall be submitted to the administrative authority.

49.25(2) If the water sample analysis detects the presence of bacteria, the disinfection procedure described in rule 567—49.24(455B) shall be repeated.

[ARC 9196C, IAB 5/14/25, effective 6/18/25]