

567—72.6(455B) Water supply and wastewater treatment facilities. The following criteria shall apply to water supply and wastewater treatment facilities:

72.6(1) Location. Water supply and wastewater treatment facilities shall be located outside of the floodway or demonstrate that the construction shall not result in a rise in upstream water surface elevations.

72.6(2) Flood protection. Flood protection for water supply and wastewater treatment facilities shall be provided to the level necessary for high damage potential buildings or building complexes unless evidence is submitted indicating the facility is of a lesser damage potential.

[ARC 9210C, IAB 5/14/25, effective 6/18/25]