

**761—115.10(306A) Vertical overhead clearance requirements.**

**115.10(1)** *Conformance to standards.* The vertical clearance for overhead utility facilities and the lateral and vertical clearances for bridges are to conform to generally accepted industry standards as well as applicable codes and regulations.

**115.10(2)** *Minimum vertical clearance.*

*a.* In no event shall the vertical clearance be less than 20 feet above the roadway for all overhead utilities.

*b.* Utility facility attachments to existing utility-owned poles are to be documented in an agreement or statement between the applicant and the pole owner authorizing the attachment for all poles not owned by the applicant and included in the permit request.

*c.* When a primary road detour has been established utilizing local jurisdiction roadways and streets, the minimum vertical clearance shall be applied to the temporary detour route at no cost to the department.

[ARC 9265C, IAB 5/14/25, effective 6/18/25]