

21—14.2 (159A) Eligible applicants. To be eligible to receive a retail motor fuel site infrastructure grant, an applicant shall:

14.2(1) Be an owner or operator of a retail motor fuel site.

14.2(2) Submit an application to the department in form and content acceptable to the department and the board.

14.2(3) Meet the following eligibility requirements established by the board:

a. The fuel storage and dispensing infrastructure may include either an aboveground or belowground storage tank and ancillary equipment.

b. Rescinded IAB 6/8/16, effective 7/13/16.

c. The storage tank must, however, be used exclusively for retail delivery to the final consumer.

d. If a tank has multiple compartments, at least one of the compartments must be used exclusively for the storage and dispensing of ethanol blended gasoline at or between E-15 and E-85, biodiesel or biodiesel blended fuel at retail. The compartment used exclusively for the storage of ethanol blended gasoline at or between E-15 and E-85, biodiesel or biodiesel blended fuel is considered the tank for purposes of this program.

e. The tank and ancillary equipment must be approved for ethanol blended gasoline at or between E-15 and E-85, biodiesel or biodiesel blended fuel use by either the Iowa department of natural resources or the state fire marshal, as evidenced by the most recent IDNR checklist.

f. The dispenser and dispenser components must be listed by an independent testing laboratory, approved by the manufacturer or approved by the state fire marshal as compatible with ethanol blended gasoline at or between E-15 and E-85. An Iowa-licensed installer has been identified to perform the installation.

g. Conversion kits. If a UL-listed E-85 dispenser conversion kit is used, it must be approved by the state fire marshal to be eligible for the E-85 grant.