

481—390.13(89) Temporary objects.

390.13(1) *Certificate to operate.* A certificate to operate a temporary object expires one year from the date of issuance or when the temporary object is disconnected.

390.13(2) *Inspections.*

a. An internal inspection and hydrostatic test pursuant to the National Board Inspection Code shall be performed on site at a new location before a temporary object is started up. Once a temporary object has been placed into normal operation, an external operating inspection shall be performed.

b. An inspection on a temporary object that remains at the same location and is in continuous service longer than one year shall be performed according to the inspection schedule of Iowa Code section 89.3.

[ARC 8887C, IAB 2/19/25, effective 3/26/25; Editorial change: IAC Supplement 7/9/25]