

481—392.5(89) Rivets. This rule applies to power boilers installed prior to July 1, 1983. When the diameter of the rivet holes in the longitudinal joints of a boiler is not known, the diameter and cross-sectional area of rivets, after driving, shall be selected from ASME Code, Section I (1971).

[ARC 8888C, IAB 2/19/25, effective 3/26/25; Editorial change: IAC Supplement 7/9/25]