

**481—393.1(89) Scope.**

**393.1(1)** This chapter sets forth requirements in addition to those contained in 481—Chapter 392 for boilers that:

- a.* Have a heating surface of 20 square feet or less;
- b.* Have a gross volume of 5 cubic feet or less, excluding casing and insulation;
- c.* Have an inside shell diameter of 16 inches or less;
- d.* Have 100 psig maximum allowable working pressure; and
- e.* Were installed prior to September 20, 2006.

**393.1(2)** For objects covered by this chapter, if there is a conflict between this chapter and 481—Chapter 392, this chapter shall govern the issue.

[ARC 8889C, IAB 2/19/25, effective 3/26/25; Editorial change: IAC Supplement 7/9/25]