

661—201.2(10A) Definitions. The definitions set forth in Iowa Code section 10A.101 are incorporated herein by reference. The following definitions also apply:

“Ambulatory surgical center” means a facility or portion thereof as defined in Iowa Code section 135R.1.

“Fire alarm system” means a system or a portion of a combination system consisting of components and circuits arranged to monitor and annunciate the status of fire alarm or supervisory signal-initiating devices and to initiate the appropriate response to those signals.

“Hospice” means a facility licensed or seeking licensure pursuant to Iowa Code section 135J.2.

“Hospital” means a facility licensed or seeking licensure pursuant to Iowa Code chapter 135B.

“Intermediate care facility” means a facility licensed or seeking licensure pursuant to Iowa Code section 135C.6 as an intermediate care facility for persons with an intellectual disability or intermediate care facility for persons with mental illness as both are defined in Iowa Code section 135C.1.

“Multiple-station smoke alarm” means two or more single-station smoke alarm devices that are capable of interconnection such that actuation of one causes the appropriate alarm signal to operate in all interconnected alarms. Interconnection may occur wirelessly for residential smoke alarms.

“NFPA” means the National Fire Protection Association, available at: www.nfpa.org. References to the form “NFPA xx,” where “xx” is a number, refer to the NFPA standard or pamphlet of the corresponding number.

“Nursing facility” means the same as defined in Iowa Code section 135C.1.

“Single-station smoke alarm” means an assembly incorporating the detector, the control equipment and the alarm-sounding device in one unit, operated from a power supply either in the unit or obtained at the point of installation or both.

“Smoke alarm” means a single- or multiple-station alarm responsive to smoke. See also “single-station smoke alarm” and “multiple-station smoke alarm.”

“Smoke detector” means a device that senses visible or invisible particles of combustion. Smoke detectors are typically listed under Underwriters Laboratories (UL) 268.

[ARC 9472C, IAB 8/6/25, effective 9/10/25]