

**661—301.3(103A) General provisions.** The provisions of the International Building Code, 2024 edition, published by the International Code Council, [www.iccsafe.org](http://www.iccsafe.org), are hereby adopted by reference as the general requirements for building construction, with the following amendments:

**301.3(1)** Delete section 101.1.

**301.3(2)** Delete section 101.2 and insert in lieu thereof the following new section:

101.2 Scope. The provisions of this code apply to the construction, alteration, movement, enlargement, replacement, repair, equipment, use and occupancy, location, maintenance, removal and demolition of every building or structure or any appurtenances connected or attached to such buildings or structures.

Exception: Detached one- and two-family dwellings and multiple single-family dwellings (townhouses) not more than three stories above grade plane in height with a separate means of egress and their accessory structures shall comply with the International Residential Code, as amended by rule 661—301.8(103A).

**301.3(3)** Delete sections 101.4.1 through 101.4.6.

**301.3(4)** Delete section 102.6 and insert in lieu thereof the following new section:

102.6 Existing Structures. The legal occupancy of any structure existing on the date of adoption of this code is permitted to continue without change, except as specifically covered in this code or the state fire code, or as deemed necessary by the building code commissioner for the general safety and welfare of the occupants and the public.

**301.3(5)** Delete sections 103, 104, 105 and sections therein.

**301.3(6)** Delete section 106.2.

**301.3(7)** Delete section 107.1 and insert in lieu thereof the following new section:

107.1 General. Submittal documents consisting of construction documents, statement of special inspections, a geotechnical report and other data shall be submitted in one or more sets with each plan review application. The construction documents shall be prepared by a responsible design professional where required by the statutes of the jurisdiction in which the project is to be constructed. Where special conditions exist, the commissioner is authorized to require additional construction documents to be prepared by a responsible design professional.

Exception: The commissioner may waive the submission of construction documents and other data if it is found that the nature of the work applied for is such that review of construction documents is not necessary to obtain compliance with this code.

**301.3(8)** Delete sections 107.3, 107.4, and 107.5 and sections therein.

**301.3(9)** Delete sections 109, 110, 111, 112, 113, 114, 115, and 116 and sections therein.

**301.3(10)** Add the following to section 202, Definitions:

“Cabin Building.” A residential building or structure the use of which is transient in nature and which is used for sleeping purposes when not classified as an Institutional Group I or when not regulated by the International Residential Code.

**301.3(11)** Add the following to section 310.2:

Cabin buildings.

**301.3(12)** Add the following new section 408.9.1:

408.9.1 Windowed Buildings. Plans and specifications for windowed buildings or portions of windowed buildings shall include a rational analysis demonstrating a tenable environment for exiting from the smoke compartment in the area of fire origin.

**301.3(13)** Delete section 423 in its entirety and insert in lieu thereof the following new section:

423 Storm Shelters.

423.1 General. Any storm shelter or weather safe room as defined by rule 661—301.38(103A) shall comply with ICC 500-2014.

423.1.1 Scope. In accordance with 661—Chapter 315, this section applies to storm shelters and weather safe rooms constructed on or after January 1, 2011. This section does not require the construction of a weather safe room or rooms for any construction project but does establish standards for design and construction of storm shelters and weather safe rooms when their construction is required by another statute, federal statute or regulation, or is incorporated voluntarily in a construction project.

**301.3(14)** Delete section 903.2.8, except for subsections 903.2.8.1 through 903.2.8.3, and insert in lieu thereof the following new section:

903.2.8 Group R. An automatic sprinkler system installed in accordance with section 903.3 shall be provided throughout all buildings with a Group R fire area.

Exception: Cabin buildings that are located in remote areas without a sufficient municipal water supply for design of a fire sprinkler system and that meet all of the following:

1. Not more than one story.
2. Not more than 750 square feet in floor area.
3. Fuel-fired heating equipment and other fuel-fired appliances are separated from sleeping areas by a one-hour fire-rated assembly.
4. Provided with fire alarm and smoke alarm systems in accord with 907 for R-1 occupancies.
5. No basements.
6. Maintain a fire separation of 20 feet from any other building or structure.
7. Comply with all applicable requirements of the state building code.

**301.3(15)** Delete section 907.2.3 and insert in lieu thereof the following new section:

907.2.3 Group E. In the absence of a complete automatic sprinkler system, a complete automatic detection system utilizing an emergency voice/alarm communication system shall be installed throughout the entire Group E occupancy. A Group E occupancy with a complete automatic sprinkler system shall be provided with a fire alarm system utilizing an emergency voice/alarm communication system in compliance with section 907.5.2.2 and installed in accordance with section 907.6. Smoke detection shall be provided in corridors at a maximum spacing of 30 feet on center, and heat or smoke detection provided in any hazardous or nonoccupied areas.

Exceptions:

1. Group E occupancies with an occupant load of less than 50.
2. Manual fire alarm boxes are not necessary in Group E occupancies where all of the following apply:
  - 2.1. Interior corridors are protected by smoke detectors with alarm verification.
  - 2.2. Auditoriums, cafeterias, gymnasiums and the like are protected by heat detectors or other approved detection devices.
  - 2.3. Shops and laboratories involving dusts or vapors are protected by heat detectors or other approved detection devices.
  - 2.4. Off-premises monitoring is provided.
  - 2.5. The capability to activate the evacuation signal from a central point is provided.
  - 2.6. In buildings where normally occupied spaces are provided with a two-way communication system between such spaces and a constantly attended receiving station from which a general evacuation alarm can be sounded, except in locations specifically designated by the fire code official.
3. Manual fire alarm boxes are not necessary in Group E occupancies where the building is equipped throughout with an approved automatic sprinkler system, the notification appliances will activate on sprinkler water flow, and manual activation is provided from a normally occupied location.
4. Emergency voice/alarm communication systems meeting the requirements of section 907.5.2.2 and installed in accordance with section 907.6 are not necessary in Group E occupancies with occupant loads of 100 or less, provided that activation of the fire alarm system initiates an approved occupant notification signal in accordance with section 907.5.

**301.3(16)** Add the following new section 1003.8:

1003.8 Frost Protection. Exterior landings at doors shall be provided with frost protection.

**301.3(17)** Add the following new section 1027.5.1:

1027.5.1 Exit Discharge Pathways. Exit discharge pathways shall be paved from all exits of the building to the public way.

**301.3(18)** Delete section 1030.1.1 and insert in lieu thereof the following new section:

1030.1.1 Bleachers, grandstands, and folding and telescopic seating that are not building elements shall comply with ICC-300, Standard for Bleachers, Folding and Telescopic Seating, and Grandstands, 2012 edition, with the following amendments to ICC-300:

*a.* Delete section 105.2 and insert in lieu thereof the following new section:

105.2 Yearly inspection. All bleachers and folding and telescopic seating installed on or after December 1, 2011, shall be inspected at least once a year in order to verify that the structure is maintained in

compliance with the provisions of this standard. All folding and telescopic seating shall also be inspected to evaluate compliance with the manufacturer's installation and operational instructions during the opening and closing of such seating. Any inspection conducted in compliance with this section may be conducted by any knowledgeable person including, but not limited to, a person who has been instructed by the manufacturer or installer as to procedures and standards for inspections of the structure being inspected and including, but not limited to, the owner of the structure or an employee of the owner of the structure. There are no further restrictions on the identity or employment of the person conducting the inspection unless otherwise provided by law. The owner shall maintain documentation of the required annual inspections, showing the date and name of the person conducting the inspection and initialed by the person conducting the inspection.

*b.* Delete section 501.2 and insert in lieu thereof the following new section:

501.2 Inspections. All tiered seating that was installed prior to December 1, 2011, shall be inspected at least once a year. The inspection may be conducted by any knowledgeable person including, but not limited to, a person who has been instructed by the manufacturer or installer as to procedures and standards for inspections of the structure being inspected and including, but not limited to, the owner of the structure or an employee of the owner of the structure. There are no further restrictions on the person conducting the inspection unless otherwise provided by law. All folding and telescopic seating shall be inspected to evaluate compliance with the manufacturer's installation and operational instructions and be inspected during the opening and closing of such seating. The owner shall maintain documentation of the inspections, which show the date and name of the person conducting the inspection and are initialed by the person conducting the inspection.

**301.3(19)** Add the following new section 1100:

1100. Any building or facility in compliance with the applicable requirements of 661—Chapter 301, Part 2, is in compliance with any applicable requirements contained in the International Building Code concerning accessibility for persons with disabilities.

**301.3(20)** Delete chapter 29.

**301.3(21)** Amend section 3001.3 by adding the following new unnumbered paragraph after the introductory paragraph:

Notwithstanding the references in Chapter 35 to editions of national standards adopted in this section, any editions of these standards adopted by the elevator safety board in 481—Chapter 372 are hereby adopted by reference. If a standard is adopted by reference in this section and there is no adoption by reference of the same standard in 481—Chapter 372, the adoption by reference in this section is of the edition identified in Chapter 35.

**301.3(22)** Delete appendices A, B, D, E, F, G, H, I, J, K, L, M, N, O, and P.

**301.3(23)** Retain Appendix C, Group U Agricultural Buildings.

**301.3(24)** Delete all references to the "International Plumbing Code" and insert in lieu thereof "state plumbing code".

**301.3(25)** Delete all references to the "International Fuel Gas Code" and insert in lieu thereof "rule 661—301.9(103A)".

**301.3(26)** Delete all references to the "International Mechanical Code" and insert in lieu thereof "state mechanical code".

**301.3(27)** Delete all references to the "International Residential Code" and insert in lieu thereof "rule 661—301.8(103A)".

**301.3(28)** Delete all references to the "International Energy Conservation Code" and insert in lieu thereof "661—Chapter 301, Part 3".

**301.3(29)** *Hospitals and health care facilities.*

*a.* A hospital, as defined in rule 661—201.2(10A), that is required to meet the provisions of the state building code is in compliance with the fire safety requirements of the state building code if the hospital is in compliance with the provisions of rule 661—201.14(10A). In any other case in which an applicable requirement of the Life Safety Code, adopted in 661—subrule 201.14(2), is inconsistent with an applicable requirement of the state building code, the hospital is in compliance with the state building code requirement if the Life Safety Code requirement is met.

*b.* A nursing facility or hospice, as defined in rule 661—201.2(10A), that is required to meet the provisions of the state building code is in compliance with the fire safety requirements of the state building code if the nursing facility or hospice is in compliance with the provisions of rule 661—201.14(10A). In any other case in which an applicable requirement of the Life Safety Code, adopted in 661—subrule 201.14(2), is inconsistent with an applicable requirement of the state building code, the nursing facility or hospice is in compliance with the state building code requirement if the Life Safety Code requirement is met.

*c.* An intermediate care facility, as defined in rule 661—201.2(10A), that is required to meet the provisions of the state building code is in compliance with the fire safety requirements of the state building code if the intermediate care facility is in compliance with the provisions of rule 661—201.14(10A). In any other case in which an applicable requirement of the Life Safety Code, as adopted in 661—subrule 201.14(2), is inconsistent with an applicable requirement of the state building code, the intermediate care facility is in compliance with the state building code requirement if the Life Safety Code requirement is met.

*d.* An ambulatory surgical center, as defined in rule 661—201.2(10A), that is required to meet the provisions of the state building code is in compliance with the fire safety requirements of the state building code if the ambulatory surgical center is in compliance with the provisions of rule 661—201.14(10A). In any other case in which an applicable requirement of the Life Safety Code, as adopted in 661—subrule 201.14(2), is inconsistent with an applicable requirement of the state building code, the ambulatory surgical center is in compliance with the state building code requirement if the Life Safety Code requirement is met.

*e.* A religious nonmedical health care institution that is required to meet the provisions of the state building code is in compliance with the provisions of the state building code if the institution is in compliance with the provisions of rule 661—201.14(10A). In any other case in which an applicable requirement of the Life Safety Code, as adopted in 661—subrule 201.14(2), is inconsistent with an applicable requirement of the state building code, the religious nonmedical health care institution is in compliance with the state building code requirement if the Life Safety Code requirement is met.

[ARC 9474C, IAB 8/6/25, effective 9/10/25]