

567—102.610(455D) Spills.

102.610(1) Any spills from leaking or cracked capacitors must be handled by placing the capacitor and any contaminated rags, clothing, and soil into a container for shipment to an EPA-approved waste disposal facility. Spills of liquid PCBs that occur outside a DOT-approved container must be cleaned and the cleanup verified by sampling as described at 40 CFR 761.130 as amended March 3, 2025. Detailed records of such cleanups and sampling must be maintained as described at 40 CFR 761.180 as amended March 3, 2025.

102.610(2) Mercury spill kits (with a mercury absorbent in the kits) must be on hand and used in the event of a mercury spill. Any waste from the cleanup of a mercury spill must be disposed of as a hazardous waste.

102.610(3) In the event a spill results in a hazardous condition, the facility must follow the requirements in 567—Chapter 105, Division I.

[ARC 0483D, IAB 8/19/26, effective 9/23/26]