

**701—64.16(452A) Terminal withdrawals—meters.** Any refinery or terminal within this state must be fixed with meters which totalize the gross gallons withdrawn. All bills of lading or manifests must show the gross gallons withdrawn. A temperature-adjusted or other method shall not be used except as it applies to liquefied petroleum gas and the sale or exchange of petroleum products between petroleum refiners. All fuel withdrawn from a refinery or terminal within this state must pass through these meters. The meters and accompanying accessories must first be approved and sealed by the department.

This rule is intended to implement Iowa Code sections 452A.2, 452A.8, 452A.15(2), 452A.59 and 452A.63.