IAC Ch 94, p.1

- 875—94.1(89) Scope. This chapter shall apply to:
  - 94.1(1) Steam boilers for operation at pressures not exceeding 15 psig;
- **94.1(2)** Hot water heating boilers for operation at pressures not exceeding 160 psig or temperatures not exceeding 250° F at or near the boiler outlet;

**94.1(3)** Hot water supply boilers. [ARC 5977C, IAB 10/20/21, effective 11/24/21]