

**481—264.6(10A) Fireworks site plan review, approval, and inspection.**

**264.6(1) Plan approval.** The retailer or community group shall submit to the department the proposed plan(s), including any required site plan(s) for the location(s) and for any building(s) or structure(s), whether permanent or temporary, that will be used for the sale and storage of fireworks. Requirements and exceptions for site plan submittal and approval are outlined on the department's website.

NOTE: Regarding the incorporation of the reference to NFPA 102, 1995 edition, Standard for Grandstands, Folding and Telescopic Seating, Tents, and Membrane Structures into NFPA 1124 concerning tents and membrane structures, Sections 7.3.5 and 7.4.8.1.2 of NFPA 1124 should be read together with Section A.7.4.8.1.2 in the Explanatory Material in Annex A to NFPA 1124 and used for the purposes of (1) determining the requirements for the means of egress in tents and membrane structures except as modified by Section 7.3.14 of NFPA 1124 for special requirements for the retail sales of consumer fireworks, and (2) to prohibit the use, discharge, or ignition of fireworks within the tent or membrane structure. The other provisions of NFPA 1124, including the sections relating to the retail sales of consumer fireworks in tents or membrane structures, remain applicable.

**264.6(2) Plans not required.** In the discretion of the department, plans may not be required in the following circumstances:

*a.* For permanent buildings or temporary structures in which only exempt amounts of first-class or second-class consumer fireworks are offered for sale, pursuant to section 7.3.1, NFPA 1124. The licensee shall make current product inventory information available to the department upon request.

*b.* For permanent buildings that were licensed in the previous year and for which there have been no changes to the site, building or floor plan. If any changes have been made, a new or updated plan shall be submitted.

*c.* For permanent buildings that are currently classified as a retail occupancy and in which second-class consumer fireworks are the only fireworks that are offered for sale.

**264.6(3) Inspections.**

*a.* Every location and any building or structure where the retail sales of consumer fireworks are conducted or where consumer fireworks are stored is subject to an inspection at any time while engaged in the retail sale of consumer fireworks.

*b.* Prior to the sale of consumer fireworks, each retail location shall satisfy one of the following requirements:

(1) A site inspection of the retail location by the department or the department's designee.

(2) Attestation at the time of the application by the person submitting the application that the retail location will comply with NFPA 1124 and these rules.

*c.* If a retail location license is revoked, the location shall be inspected in accordance with subparagraph 264.6(3) "b"(1) prior to engaging in the sale of consumer fireworks the following year.

[ARC 7872C, IAB 4/17/24, effective 5/22/24; Editorial change: IAC Supplement 11/26/25]