

**875—92.3(89) Codes adopted by reference.**

**92.3(1)** *Installations from July 1, 1983, to December 31, 1988.* All installations from July 1, 1983, to December 31, 1988, including reinstalled boilers, shall be installed in accordance with the requirements of the ASME Code for Boilers and Pressure Vessels Section I (1983). Boiler installations shall also comply with ANSI/ASME CSD-1 (1982), excluding the provisions for listing or labeling by a nationally recognized testing agency.

**92.3(2)** *Installations from January 1, 1989, to December 31, 1990.* All installations from January 1, 1989, to December 31, 1990, including reinstalled boilers, shall be installed in accordance with the requirements of the ASME Code for Boilers and Pressure Vessels Section I (1986 with 1988 addenda). Boiler installations shall also comply with ANSI/ASME CSD-1 (1986 with 1988 addenda), excluding the provisions for listing or labeling by a nationally recognized testing agency.

**92.3(3)** *Installations from January 1, 1991, to June 30, 1995.* All installations from January 1, 1991 to June 30, 1995, including reinstalled boilers, shall be installed in accordance with the requirements of the ASME Code for Boilers and Pressure Vessels Section I (1989) with 1990 addenda). Boiler installations shall also comply with ANSI/ASME CSD-1 (1988 with CSD-1a-1989 and CSD-1b-1990 addenda), excluding the provisions for listing or labeling by a nationally recognized testing agency.

**92.3(4)** *Installations from July 1, 1996, to December 31, 1997.* All installations between July 1, 1996, and December 31, 1997, including reinstalled boilers, shall be installed in accordance with the requirements of the ASME Code for Boilers and Pressure Vessels Section I (1992 with 1994 addenda) or with the requirements of recognized national or international standards such as DIN, BSI, JIS, or CSA. Gas-fired jacketed steam kettles may be installed provided they are designed, installed, inspected and stamped in accordance with ASME Code for Boilers and Pressure Vessels Section VIII, Division I, Appendix 19 (1995). Unfired steam boilers shall not be constructed under the provisions of Section VIII. Installations shall also comply with ANSI/ASME CSD-1 (1995 with 1996 addenda).

**92.3(5)** *Installations from January 1, 1998, to December 31, 2000.* All installations from January 1, 1998, to December 31, 2000, including reinstalled boilers, shall be installed in accordance with the requirements of the ASME Code for Boilers and Pressure Vessels Section I (1995 with 1997 addenda) or with the requirements of recognized national or international standards such as DIN, BSI, JIS, or CSA. Unfired steam boilers shall not be constructed under the provisions of Section VIII. Boiler installations shall also comply with ANSI/ASME CSD-1 (1995 with 1996 addenda).

**92.3(6)** *Installations from January 1, 2001, to September 20, 2006.* All installations from January 1, 2001, to September 20, 2006, including reinstalled boilers, shall be installed in accordance with the requirements of the ASME Code for Boilers and Pressure Vessels Section I (1998 with 1999 and 2000 addenda) or with the requirements of recognized national or international standards such as DIN, BSI, JIS, or CSA. Unfired steam boilers shall not be constructed under the provisions of Section VIII. Boiler installations shall also comply with ANSI/ASME CSD-1 (1995 with 1999 addenda).

**92.3(7)** *Installations after September 20, 2006.* On or after September 20, 2006, all installations, including reinstalled boilers, shall be installed, designed, manufactured, stamped and inspected in accordance with the requirements of the ASME Code for Boilers and Pressure Vessels Section I (2004 with 2005 addenda) or with the requirements of recognized national or international standards such as DIN, BSI, JIS, or CSA. Unfired steam boilers shall not be constructed under the provisions of Section VIII. Power boiler installations from 400,000 to 12,500,000 Btu's shall also comply with ANSI/ASME CSD-1 (2004).