23

SENATE FILE 2/12

BY COMMITTEE ON STATE GOVERNMENT

(SUCCESSOR TO SSB 2063) (COMPANION TO HF 2165)

Passed Senate, Date 2/18/98 Passed House, Date 2/23/98

Vote: Ayes 48 Nays 0 Vote: Ayes 92 Nays 0

Approved 2, 1998

## A BILL FOR

1 An Act relating to the state fire marshal, including the installation of automatic fire extinguishing systems in new construction. 4 BE IT ENACTED BY THE GENERAL ASSEMBLY OF THE STATE OF IOWA: 5 6 7 8 9 10 11 1.2 13 14 15 16 17 18 19 20 21 22

# S.F. 2183 H.F.

- 1 Section 1. Section 100.39, unnumbered paragraph 1, Code
- 2 1997, is amended to read as follows:
- 3 All buildings that-are approved for construction, after
- 4 August-157-1975 July 1, 1998, that exceed four stories in
- 5 height, or sixty-five seventy-five feet above grade, shall
- 6 require the installation of an approved automatic fire
- 7 extinguishing system designed and installed in conformity with
- 8 rules promulgated by the state fire marshal pursuant to this
- 9 chapter.
- 10 Sec. 2. Section 101.2, Code 1997, is amended by striking
- Il the section and inserting in lieu thereof the following:
- 12 101.2 SCOPE OF RULES.
- 13 Except as otherwise provided in this chapter, the rules
- 14 shall be in substantial compliance with the standards of the
- 15 national fire protection association relating to flammable
- 16 liquids and liquefied petroleum gases.
- 17 Sec. 3. Section 101.12, Code 1997, is amended to read as
- 18 follows:
- 19 101.12 ABOVEGROUND PETROLEUM TANKS AUTHORIZED.
- 20 Rules of the state fire marshal shall-permit permitting
- 21 installation of aboveground petroleum storage tanks for retail
- 22 motor vehicle fuel outlets as-permitted-by-the-tatest-edition
- 23 of-the shall be in substantial compliance with the applicable
- 24 standards of the national fire protection association rule
- 25 30A, and shall be subject to the approval of the governing
- 26 body of the local governmental subdivision with jurisdiction
- 27 over the site of the outlet.
- 28 Sec. 4. Section 100.32, Code 1997, is repealed.
- 29 EXPLANATION
- 30 This bill repeals Code section 100.32 that prevents the
- 31 fire marshal from providing fire safety information and
- 32 education materials when moneys are not appropriated for that
- 33 purpose, increases the new building construction neight levels
- 34 at which automatic fire extinguishing systems must be
- 35 installed from 65 feet to 75 feet, and requires that the state

```
i fire marshal's administrative rules be in substantial
2 compliance with the standards of the national fire protection
3 association relating to aboveground petroleum storage tanks,
4 flammable liquids, and liquefied petroleum gases.
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
```

Borlang Szymoniak Tinsman

SSB 2063

Succeeded By

SENATE/HOUSE FILESF/HF 2182

BY (PROPOSED DEPARTMENT OF

PUBLIC SAFETY BILL)

Passed	Senate,	Date	Passed	House,	Date	
Vote:	Ayes	Nays	Vote:	Ayes	Nays _	
Approved						

## A BILL FOR

1 An Act relating to the state fire marshal, including the

2 installation of automatic fire extinguishing systems in new

3 construction.

4 BE IT ENACTED BY THE GENERAL ASSEMBLY OF THE STATE OF IOWA:

- 1 Section 1. Section 100.39, unnumbered paragraph 1, Code
- 2 1997, is amended to read as follows:
- 3 All buildings that-are approved for construction, after
- 4 August-157-1975 July 1, 1998, that exceed four stories in
- 5 height, or sixty-five seventy-five feet above grade, shall
- 6 require the installation of an approved automatic fire
- 7 extinguishing system designed and installed in conformity with
- 8 rules promulgated by the state fire marshal pursuant to this
- 9 chapter.
- 10 Sec. 2. Section 101.2, Code 1997, is amended by striking
- 11 the section and inserting in lieu thereof the following:
- 12 101.2 SCOPE OF RULES.
- 13 Except as otherwise provided in this chapter, the rules
- 14 shall be in substantial compliance with the standards of the
- 15 national fire protection association relating to flammable
- 16 liquids and liquefied petroleum gases.
- 17 Sec. 3. Section 101.12, Code 1997, is amended to read as
- 18 follows:
- 19 101.12 ABOVEGROUND PETROLEUM TANKS AUTHORIZED.
- 20 Rules of the state fire marshal shall-permit permitting
- 21 installation of aboveground petroleum storage tanks for retail
- 22 motor vehicle fuel outlets as-permitted-by-the-latest-edition
- 23 of-the shall be in substantial compliance with the applicable
- 24 standards of the national fire protection association rule
- 25 30A, and shall be subject to the approval of the governing
- 26 body of the local governmental subdivision with jurisdiction
- 27 over the site of the outlet.
- 28 Sec. 4. Section 100.32, Code 1997, is repealed.
- 29 EXPLANATION
- 30 This bill repeals Code section 100.32 that prevents the
- 31 fire marshal from providing fire safety information and
- 32 education materials when moneys are not appropriated for that
- 33 purpose, increases the new building construction height levels
- 34 at which automatic fire extinguishing systems must be
- 35 installed from 65 feet to 75 feet, and requires that the state

S.F. H.F.

```
1 fire marshal's administrative rules be in substantial
2 compliance with the standards of the national fire protection
3 association relating to aboveground petroleum storage tanks,
4 flammable liquids, and liquefied petroleum gases.
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
```

LSB 3086DP 77 kh/sc/14

DEPARTMENT OF PUBLIC SAFE
PAUL H. WIECK II, COMMISSIONS

TO:

Members of the General Assembly

FROM:

Paul Wieck II, Commissioner

DATE:

November 17, 1997

RE:

Proposed Amendments to State Fire Marshal Code

The State Fire Marshal has proposed the attached amendments to Chapters 100 and 101 to bring code language into compliance with current practice and to provide consistency with rule-making. The sections are outlined below:

- 1. Amends section 100.39 to reflect language in model building codes, including the State and the Uniform Building Code that requires installation of automatic fire extinguishing systems in buildings 75 feet above grade. Few buildings would be affected by this change since the four-story provisions generally make sprinklers required at less than either 65 or 75 feet. High-rise building requirements generally become effective at 75 feet.
- 2. Amends 101.2 to conform rules to existing practice which is to maintain substantial compliance with standards of the national fire protection association.
- 3. Amends 101.12 in order to be consistent with administrative rule-making. (The date of the edition of the national fire protection association that is adopted is part of the rule-making process.)
- 4. Strikes section 100.32 which seems to require that the state fire marshal's office provide fire safety information and educational material but that no money shall be expended for such purpose. Taken literally, it would appear to prohibit the fire marshal from participating in any type of public fire safety education unless there were a line-item appropriation. The original language was codified in 1911, amended in 1958, and does not reflect current practice. The current language reads:

"The state fire marshal may cooperate with any recognized agency in the education of the public in fire safety, but no money shall be expended for such purpose except it be specifically appropriated by the legislature for that purpose. Any such agency receiving appropriations of state money for fire safety purposes shall annually file with the auditor of the state an itemized statement of all its receipts and expenditures. The state fire marshal may cause fire safety information and educational material to be printed and distributed to schools, fire departments, or other interested persons or organizations."







### SENATE FILE 2182

### AN ACT

RELATING TO THE STATE FIRE MARSHAL, INCLUDING THE INSTALLATION OF AUTOMATIC FIRE EXTINGUISHING SYSTEMS IN NEW CONSTRUCTION.

BE IT ENACTED BY THE GENERAL ASSEMBLY OF THE STATE OF IOWA:

Section 1. Section 100.39, unnumbered paragraph 1, Code 1997, is amended to read as follows:

All buildings that-are approved for construction, after August-157-1975 July 1, 1998, that exceed four stories in height, or sixty-five seventy-five fast above grade, shall require the installation of an approved automatic fire extinguishing system designed and installed in conformlty with rules promulgated by the state fire marshal pursuant to this chapter.

Sec. 2. Section 101.2, Code 1997, is amended by striking the section and inserting in lieu thereof the following:

101.2 SCOPE OF RULES.

Except as otherwise provided in this chapter, the rules shall be in substantial compliance with the standards of the national fire protection association relating to flammable liquids and liquefied petroleum gases.

Sec. 3. Section 101.12, Code 1997, is amended to read as follows:

101.12 ABOVEGROUND PETROLEUM TANKS AUTHORIZED.

Rules of the state fire marshal shatl-permit permitting installation of aboveground petroleum storage tanks for retail motor vehicle fuel outlets as-permitted-by-the-latest-edition of-the shall be in substantial compliance with the applicable standards of the national fire protection association rule 36A, and shall be subject to the approval of the governing

Senate File 2182, p. 2

body of the local governmental subdivision with jurisdiction over the site of the outlet.

Sec. 4. Section 100.32, Code 1997, is repealed.

MARY E. KRAMER
President of the Senate

RON J. CORBETT
Speaker of the House

I hereby certify that this bill originated in the Senate and is known as Senate File 2182, Seventy-seventh General Assembly.

MARY PAT GUNDERSON
Secretary of the Senate

approved / Merch. 199

TERRY E. BRANSTAD

Governor