

Senate Study Bill 2063

Bill Text

PAG LIN

1 1 Section 1. Section [100.39](#), unnumbered paragraph 1, Code
1 2 1997, is amended to read as follows:
1 3 All buildings
.
~~that are~~
- approved for construction
.
~~,~~
- after
1 4
.
~~August 15, 1975~~
- ~~July 1, 1998~~, that exceed four stories in
1 5 height, or
.
~~sixty five~~
- ~~seventy-five~~ feet above grade, shall
1 6 require the installation of an approved automatic fire
1 7 extinguishing system designed and installed in conformity with
1 8 rules promulgated by the state fire marshal pursuant to this
1 9 chapter.
1 10 Sec. 2. Section [101.2](#), Code 1997, is amended by striking
1 11 the section and inserting in lieu thereof the following:
1 12 101.2 SCOPE OF RULES.
1 13 Except as otherwise provided in this chapter, the rules
1 14 shall be in substantial compliance with the standards of the
1 15 national fire protection association relating to flammable
1 16 liquids and liquefied petroleum gases.
1 17 Sec. 3. Section [101.12](#), Code 1997, is amended to read as
1 18 follows:
1 19 101.12 ABOVEGROUND PETROLEUM TANKS AUTHORIZED.
1 20 Rules of the state fire marshal
.
~~shall permit~~
- ~~permitting~~
1 21 installation of aboveground petroleum storage tanks for retail
1 22 motor vehicle fuel outlets
.
~~as permitted by the latest edition~~
-
1 23
.
~~of the~~
- ~~shall be in substantial compliance with the applicable~~
1 24 ~~standards of the~~ national fire protection association
.
~~rule~~
-
1 25
.
~~30A~~
-, ~~and shall be~~ subject to the approval of the governing
1 26 body of the local governmental subdivision with jurisdiction
1 27 over the site of the outlet.
1 28 Sec. 4. Section [100.32](#), Code 1997, is repealed.
1 29

EXPLANATION

1 30 This bill repeals Code section 100.32 that prevents the
1 31 fire marshal from providing fire safety information and
1 32 education materials when moneys are not appropriated for that
1 33 purpose, increases the new building construction height levels
1 34 at which automatic fire extinguishing systems must be
1 35 installed from 65 feet to 75 feet, and requires that the state
2 1 fire marshal's administrative rules be in substantial
2 2 compliance with the standards of the national fire protection
2 3 association relating to aboveground petroleum storage tanks,
2 4 flammable liquids, and liquefied petroleum gases.
2 5 LSB 3086DP 77
2 6 kh/sc/14